

**Section 3**

**Combined Lead Consumer Notice and Certification Form**

School Name: Calera Intermediate Date: March 6, 2018

**LEAD CONSUMER NOTICE  
ANALYTICAL RESULTS FOR LEAD TAP WATER MONITORING**

Our school facility voluntarily collected tap water samples to determine the lead levels in our school's drinking water. The school facility and sampling sites were selected for this monitoring as part of our overall sampling plan. This notice is provided to you with the analytical results of the water sample collected at the school facility.

Sample location: Nurse Station Sink Sample collection date: 1/11/18

Analytical Lead result, in mg/L (milligrams per liter): <0.003ppb

Sample location: Kitchen 3 Comp Sink Sample collection date: 1/11/18

Analytical Lead result, in mg/L (milligrams per liter): <0.003ppb

Sample location: Water Fountain @ Rm 100 Sample collection date: 1/11/18

Analytical Lead result, in mg/L (milligrams per liter): <0.003ppb

Sample location: \_\_\_\_\_ Sample collection date: \_\_\_\_\_

Analytical Lead result, in mg/L (milligrams per liter): \_\_\_\_\_

Sample location: \_\_\_\_\_ Sample collection date: \_\_\_\_\_

Analytical Lead result, in mg/L (milligrams per liter): \_\_\_\_\_

**Note:** All sample results may be shown on one notice, or on separate individual notices.

**Definitions**

*Action Level (AL):* The action level is a concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a school facility must follow. The lead action level for schools is 0.020 mg/L.

**What are the health effects of lead and how can I reduce my exposure?**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and plumbing. The public water system is responsible for providing drinking water that meets all federal and state standards, but cannot control the variety of materials used in plumbing components.

When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using the water and using only cold water for drinking or cooking. Information on lead in drinking water and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov>.

**Who can I contact at my school for more information?** Haley Franks

**Consumer Notice Instructions:**

Schools should complete the consumer notice and distribute the notice to each building that was tested.

**Consumer Notice Content**

The consumer notice should include the mandatory language in the example provided with these instructions. It should be multilingual, where appropriate.

**Distribution of the Consumer Notice**

Schools should provide the consumer notice to all the people served at each building that was a part of the sampling plan. The consumer notice should be provided within 30 days of receiving the sampling results. ADEM recommends schools provide the consumer notice as soon as available, especially if the result is elevated, to allow affected persons to take corrective actions in a more timely manner.

Date Consumer Notice completed: \_\_\_\_\_

**DELIVERY CERTIFICATION**

I certify under penalty of law that I am familiar with the information submitted in this document and that it is true, accurate, and complete.

**Name (print or type)** \_\_\_\_\_ **Title** \_\_\_\_\_

**Signature** \_\_\_\_\_ **Date** \_\_\_\_\_